

8

7

6

5

4

3

200470

1

THIS DRAWING AND THE DATA DISCLOSED HEREIN OR HEREWITH IS CONFIDENTIAL AND PROPRIETARY AND IS NOT TO BE REPRODUCED, USED, OR DISCLOSED IN WHOLE OR IN PART TO ANYONE WITHOUT THE EXPRESSED WRITTEN PERMISSION OF MULTIQUIP COMPANY.

REVISIONS				
ZONE	LTR	DESCRIPTION	DATE	APPROVED

TOP VIEW

END VIEW

SIDE VIEW

FRONT VIEW

TANK FITTINGS :

A) 2" NPT NORMAL VENT FITTING
 B) 5" NPT EMERGENCY VENT FITTING PER NFPA 30 (qty 2)
 C) 2" NPT FUEL FILL FITTING
 D) 2" NPT FOR REMOVABLE FUEL SUPPLY DIP TUBE - 1/2" NPT
 E) 2" NPT FOR REMOVABLE FUEL RETURN DIP TUBE - 1/2" NPT
 F) 2" NPT FUEL LEVEL GAUGE FITTING
 G) 2" NPT FOR OPTIONAL LOW LEVEL ALARM SWITCH
 H) 2" NPT FOR OPTIONAL HIGH FUEL LEVEL SWITCH
 J) 1/2" NPT FOR OPTIONAL FUEL IN BASIN SWITCH
 S) 1/2" NPT FOR BASIN DRAIN

UNLESS OTHERWISE SPECIFIED
 DIMENSIONS ARE IN INCHES
 TOLERANCES ARE :
 FRACTIONS DECIMALS ANGLES
 ± .XX ± ±
 .XXX ±

CUSTOMER
 JOB NO.
 APPROVALS DATE
 DRAWN J. TRAN 10-8-03
 CHECKED
 SALESMAN

MQ POWER
 TEL: (310) 537-3700/FAX: (310) 632-2656
 18910 WILMINGTON AVENUE
 CARSON, CA 90746

DERIVED FROM
 SAUK TECHNOLOGIES
 REV DATE
 CAD CODE
 200470

MATERIAL
 FINISH
 DO NOT SCALE DRAWING

FUEL TANK, 24HR (1000GAL.) D.W.
 KD450V TO KD500V
 SIZE D
 SCALE 1/12

DWG. NO. 200470
 SHEET 1 / 1

8

7

6

5

4

3

2

1

200470